



Republic of the Philippines
DEPARTMENT OF AGRICULTURE
Western Visayas

SUPPLEMENTAL / BID BULLETIN

This Addendum is issued to modify or amend items in the Bid Document (*Invitation to Bid and Philippine Bidding Documents*) for **Procurement of Works for the Establishment of Jolongajog Solar-Powered Irrigation System/IB No. 2022-057(AMV)**.

On Invitation to Bid and Philippine Bidding Documents:

2. The Department of Agriculture-Western Visayas now invites bids for the Procurement of Works for the Establishment of Jolongajog Solar-Powered Irrigation System at Brgy. Jolongajog, Pontevedra, Capiz with the following specifications:

C. Solar Pump (Submersible)

The pump must be tested by the AMTEC;

1. Brand New;
2. 5 Hp Electric Motor Submersible Pump, Coupled (Minimum). Pump power may change/varies based on the pumping test result, drilling and actual total dynamic head of site.
3. Pump Specifications;
 - a. 4 inches submersible pump coupled into the electric motor
 - b. Capacity of 114.61 cubic meter per day or based on the result of pumping test
 - c. Total Dynamic Head of 27 meters (Minimum)
 - d. Pump Efficiency of 68 percent **(Minimum)**

For guidance and information of all concerned.

MARIA TERESA T. SOLIS
BAC Vice-Chairperson